



333 Pfingsten Road
Northbrook, Illinois 60062-2096
United States Country Code (1)
(847) 272-8800
FAX No. (847) 272-8129
<http://www.ul.com>

February 15, 1999

Won-Door Corp.
Mr. Carl Goodman
1865 S, 3480 W.
Salt Lake City, UT 84104



Our Reference: File R6799 - Special Purpose Type Fire Doors

Dear Mr. Goodman:

This is to confirm that your single slide and bi-parting folding doors with a 250° F maximum temperature rise are eligible to bear the Underwriters Laboratories Inc. Classification Marking for doors rated up to and including 3 hours.

The Classification/Listing Mark of Underwriters Laboratories Inc. on the product is the only method provided by Underwriters Laboratories Inc. to identify products which have been produced under its Classification and Follow-Up Service. As always, the final acceptance of the installation is up to the local Authority Having Jurisdiction.

If we can be further assistance please feel free to contact us.

Very truly yours,

LAURA HORN
Technical Correspondent
Engineering Services