



Incorporated 1920

Underwriters' Laboratories of Canada

An Affiliate of Underwriters Laboratories Inc.

CR 2329
30789

December 15, 1999

Mr. Carl Goodman
Chief Engineer
Won-Door Corporation
1865 South, 3480 West
Salt Lake City, Utah 84014
USA

Subject: Special Purpose Fire Door and Frame Assemblies

Dear Mr. Goodman

This is to confirm that the following Won-Door models are Listed by Underwriters' Laboratories of Canada and are eligible to bear the ULC label:

<u>Model</u>	<u>Width, mm</u>	<u>Height, mm</u>	<u>Rating (temp. rise if applicable)</u>
Fireguard 20	3972	3562	20 min
Fireguard 60	3972	3562	1 h
Fireguard 90	3972	3562	1 ½ h
Fireguard 180	3972	3562	3 h
Fireguard 60TR	3988	3550	1 h (250°C, 30 min)
Fireguard 90TR	3988	3550	1 ½ h (250°C, 30 min)
Fireguard 180TR	3785	3550	3 h (250°C, 30 min)

In addition, these models may be labelled for oversize openings, subject to the review of each installation by ULC.

..../2


GENERAL OFFICES AND TESTING STATION:
7 Crouse Road, Scarborough, Ontario, Canada M1R 3A9
Telephone: (416) 757-3611 or 1-800-INFO-ULC
Fax: (416) 757-8916
Visit us at: www.ulc.ca e-mail: ulcinfo@ulc.ca



Page 2
Mr. Goodman
December 16, 1999

We trust that this is the information you require. Should further questions arise, please do not hesitate to contact us.

Yours, very truly,

A handwritten signature in cursive script, appearing to read "Howard Spice".

Howard Spice, P.Eng.
Project Engineer
Construction Materials

HS/lr