



333 Pfingsten Road
Northbrook, Illinois 60062-2096
United States Country Code (1)
(847) 272-8800
FAX No. (847) 272-8129
<http://www.ul.com>

August 7, 2000

Won-Door Corporation
Mr. Carl Goodman
1865 South 3480 West
Salt Lake City, Utah 84104

Our Reference: R6799
Subject: Positive Pressure Testing

Dear Mr. Goodman:

This is in response to your June 20, 2000 letter regarding the above subject for your fire doors covered under UL File R6799.

We have successfully tested your Fire Guard 20 through 180 (3 H) Special Purpose Fire Doors both nontemperature rise and temperature rise to the various Standards UL 263, ISO 3008 under positive pressure requirements. These would meet the present requirements of UL 10C.

The different fire ratings all use similar door construction where the liner varies and the width of the panel connectors (thicker liner requires a wider outside panel connector). The surrounding drywall construction, i.e. pockets, header and strike wall change to meet basic fire requirements for the hourly rating.

If we can be of further service, please contact the undersigned.

Very truly yours,

DICK WALTHER
Senior Engineering Associate
Conformity Assessment Services
Dept. 3011B

Reviewed by:

DANIEL J. KAISER
Engineering Group Leader
Conformity Assessment Services
Dept. 3011B

DW/DJK:tjm

7797-FPCORR/R6799